

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: October 17, 2025
 Sample ID: 25033
 Date Analyzed: 9/25/25
 WO Number: 250917032

Customer: HFM BOCES
 Address: 2755 Route 67, Johnstown, New York 12095
 Sample Location: See Chart
 Sample Point: See Chart
 Water Source: Municipal Water
 Chlorinated: Yes

Collection Date: 9/17/25
 Collection Time: See Chart
 Collected by: Angelo E. Finateri
 Potable: Yes
 Grab/Composite: Grab
 Receipt Temp: Ambient

Sample #	HFM BOCES Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
	A Wing 1st Floor				5.0		EPA 200.8 REV 5.4
41	A108 - break room sink	6:17 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
17	Drinking fountain near elevator room	6:16 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
					5.0		EPA 200.8 REV 5.4
	A Wing 2nd Floor				5.0		EPA 200.8 REV 5.4
33	A204 - Break room sink - Business Office	6:51 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
					5.0		EPA 200.8 REV 5.4
	B Wing 1st Floor				5.0		EPA 200.8 REV 5.4
24	B104 - Nurse's Office room sink #1	6:15 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
46	B108 - Criminal Justice sink	6:14 AM	09/17/25	1.1	5.0		EPA 200.8 REV 5.4
15	B115 - Hand wash sink in Cosmetology	6:10 AM	09/17/25	1.4	5.0		EPA 200.8 REV 5.4
16	B111 - Hand wash sink	6:12 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
40	Drinking fountain near C105 (By Fire Exit C)	6:08 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
	B Wing 2nd Floor				5.0		EPA 200.8 REV 5.4
10	B216 - Medical assisting sink #1 (left)	7:03 AM	09/17/25	1.3	5.0		EPA 200.8 REV 5.4
29	B216 - Medical assisting sink #2 (right)	7:04 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
43	B209 - LPN sink #1 (left)	7:00 AM	09/17/25	1.5	5.0		EPA 200.8 REV 5.4
20	B207 - LPN sink	6:55 AM	09/17/25	1.5	5.0		EPA 200.8 REV 5.4
2	B203 A - Graphics lab sink	6:53 AM	09/17/25	1.5	5.0		EPA 200.8 REV 5.4
38	Drinking fountain near Boy's room	7:06 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
4	B209 - Sink #2 (right)	7:01 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
12	B216 A - Medical assisting sink	7:04 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: October 17, 2025
 Sample ID: 25033
 Date Analyzed: 9/25/25
 WO Number: 250917032

Customer:	HFM BOCES	Collection Date:	9/17/25
Address:	2755 Route 67, Johnstown, New York 12095	Collection Time:	See Chart
Sample Location:	See Chart	Collected by:	Angelo E. Finateri
Sample Point:	See Chart	Potable:	Yes
Water Source:	Municipal Water	Grab/Composite:	Grab
Chlorinated:	Yes	Receipt Temp:	Ambient

Sample #	HFM BOCES Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
	C Wing				5.0		EPA 200.8 REV 5.4
22	C108 - Culinary sink #1 (C - 108 - 3 Dish room)	5:46 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
23	C108 - Culinary sink #2 (C - 108 - 3 Dish room)	5:49 AM	09/17/25	3.5	5.0		EPA 200.8 REV 5.4
47	C108 - Room sink - #1	5:59 AM	09/17/25	1.4	5.0		EPA 200.8 REV 5.4
****	C109 - Culinary lab sink #1 (Not testing because posted Faucets for Hand Wash only)	****	09/17/25	****	5.0		EPA 200.8 REV 5.4
28	C109 - Culinary lab sink #2	5:14 AM	09/17/25	3.5	5.0		EPA 200.8 REV 5.4
37	C109 - Culinary lab sink #3 (left)	5:21 AM	09/17/25	2.0	5.0		EPA 200.8 REV 5.4
11	C109 - Culinary lab sink #4 (right)	5:22 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
39	C109 - Culinary sink #5	5:28 AM	09/17/25	1.8	5.0		EPA 200.8 REV 5.4
27	C108 - Pedal sink- #5 (Labeled #2)	5:00 AM	09/17/25	1.1	5.0		EPA 200.8 REV 5.4
9	C109 - Culinary lab sink #6 (Washer Spray)	5:30 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
26	C109 - Culinary lab ice machine	5:04 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
36	C109 - Culinary lab sink #7	5:35 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
50	C108 - Culinary sink #4 (left) (Labeled #3)	6:01 AM	09/17/25	2.9	5.0		EPA 200.8 REV 5.4
7	C108 - Culinary sink #3 (right) (Labeled #4)	6:02 AM	09/17/25	1.8	5.0		EPA 200.8 REV 5.4
35	C108 - Culinary sink 6 (Labeled #5)	6:04 AM	09/17/25	4.5	5.0		EPA 200.8 REV 5.4
30	C - 109 - Dishwasher spray	4:58 AM	09/17/25	3.6	5.0		EPA 200.8 REV 5.4
6	C - 109 - Dishwasher room sink	4:59 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
****	C-109 - Hand wash #8 (Not testing because posted Faucets for Hand Wash only)	****	09/17/25	****	5.0		EPA 200.8 REV 5.4
****	C - 109 - Hand wash #9(Not testing because posted Faucets for Hand Wash only)	****	09/17/25	****	5.0		EPA 200.8 REV 5.4
****	C - 108 - Hand wash #6(Not testing because posted Faucets for Hand Wash only)	****	09/17/25	****	5.0		EPA 200.8 REV 5.4
	D Wing				5.0		EPA 200.8 REV 5.4
48	D108 F - Kitchen sink	6:47 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
49	D122 A - Sink in fish hatchery	6:34 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
1	D123 A - Sink in Encon lab	6:40 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4
13	Drinking Fountain near D122	6:44 AM	09/17/25	ND	5.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: October 17, 2025
 Sample ID: 25033
 Date Analyzed: 9/25/25
 WO Number: 250917032

Customer: HFM BOCES	Collection Date: 9/17/25
Address: 2755 Route 67, Johnstown, New York 12095	Collection Time: See Chart
Sample Location: See Chart	Collected by: Angelo E. Finateri
Sample Point: See Chart	Potable: Yes
Water Source: Municipal Water	Grab/Composite: Grab
Chlorinated: Yes	Receipt Temp: Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

All test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

**Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:*

1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).
2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.

Qualifiers Key:

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

< = Less than
 > = Greater than
 ≈ = Approximately
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350